

Table of Contents

Table of Contents	Page 1
Approvals	Page 1
Attention	Page 1
Specification	Page 2
Model Description & Part Number	-
Operation	Page 2
Pressure Connection & Mounting AAA2-4	-
Pressure Connection & Mounting AAA2-6	Page 3
Installation Position	Page 3
Application & Connection Examples	-
Wiring	-
Operation & Adjustment	Page 4
Maintenance & Testing	-
Accessories & Replacement	Page 5

Approvals



UL Listed: UL 353 File # MH 16628



CSA Certificate: CSA C22.2 No. 14 File # 201527

APPROVED

FM Approved: Class 3510, 3530 File # J.I.0D6A1.AF

Commonwealth of Massachusetts Approved Product Approval code G3-0106-191

Attention









The installation and maintenance of this product must be done under the supervision of an experienced and trained specialist. Never perform work if gas pressure or power is applied, or in the presence of an open flame.

Please read the instruction before installing or operating. Keep the instruction in a safe place. You find the instruction also at www. dungs.com. If these instructions are not heeded, the result may be personal injury or damage to property.

Any adjustment and applicationspecific adjustment values must be made in accordance with the equipment manufacturers instructions.



Safety first **O.K.**



Check the ratings in the specifications to verify that they are suitable for your application.

Combustion Controls

On completion of work on the pressure switch, perform a leakage and function test.

This product is intended for installations covered by, but not limited to, the following fuel gas codes and standards: NFPA 54, IFGC (International Fuel Gas Code) or CSA B149.1 (for Canada) or the following equipment codes and standards: NFPA 37, NFPA 85, NFPA 86, ANSI Z83.4/ CSA 3.7, ANSI Z83.18/CSA 4.9, ANSI Z21.13, CSD-1, UL 795, CSA B149.1 or CSA B149.3

Explanation of symbols 1, 2, 3 ... = Action

= Instruction

1 ... 5

MC • Karl Dungs, Inc. • AA...A2 • Edition 2017.07 • P/N 261393

Specification

AA...A2

SPDT differential pressure switch in pressure and vacuum ranges. The differential pressure acts via the diaphragm against the force of the setting spring on the microswitch. The pressure switch operates without any auxiliary power.





Max. Operating Pressure MOP = 7 PSI (500 mbar)



Electrical Connection Screw terminals via 1/2"NPT conduit connection



Ambient / Medium Temperature -40 °F ... +140 °F (-40 °C ... +60 °C)

Air and non-aggressive gases only.

Not suitable for natural gas, propane, butane or other combustable

Materials in contact with Gas Housing: Polycarbonate Switch: Polycarbonate

Diaphragm: NBR-based rubber

Switching contact: Silver (Ag)

Gases

gases.





Enclosure NEMA Type 4

Contact Rating

3 A inductive @ 120 VAC 1 A max. @ 12 - 48 VDC

5 A resistive,




Switch SPDT Switch action Pressure, vacuum of differential pressure switch

Model Description & Part Number						
Туре	Version	Description	Order No.	Setting range in. W.C.	Switching hysteresis in. W.C.	Factory Calibration
AA-A2-4 pressure switch	AA-A2-4-2 AA-A2-4-3 AA-A2-4-5 AA-A2-4-6	Hose connection Hose connection Hose connection Hose connection	266910 266911 266912 266913	0.16 - 1.20 0.40 - 4.00 2.00 - 20.00 12.00 - 60.00		↑□
AA-A2-6 pressure switch	AA-A2-6-2 AA-A2-6-3 AA-A2-6-5 AA-A2-6-6	Threaded connection Threaded connection Threaded connection Threaded connection	266932 266934 266936 266938	0.16 - 1.20 0.40 - 4.00 2.00 - 20.00 12.00 - 60.00		ţ₫

Operation

Definition of switching hysteresis **D**p

The pressure difference between the upper and lower switching pressures.



MC • Karl Dungs, Inc. • AA...A2 • Edition 2017.07 • P/N 261393

Pressure Connection & Mounting AA...A2-4

AA...A2-4 Hose Connection

- (1) Pressure connection (+) Ø 0.18"
- (2) Pressure connection (-) Ø 0.18"

AA...A2-4 Mounting Procedure

- Use suitable hoses for the medium.
- Use a maximum 5/32" ID, hose
- Secure the hoses with a cable tie or a cable clip.

Pressure Connection & Mounting AA...A2-6

AA...A2-6 Threaded Connection


- Pressure connection (+) 1/4" NPT
- Pressure connection (-) 1/8" NPT
- Test nipple p (+) Ø 0.18"

AA...A2-6 Mounting Procedure

- Apply good quality pipe sealant to the male threads only.
- Use 13/16" Wrench to secure the switch to the pipe. DO NOT Exceed 45 lb-in of Torque on 1/8" Connections DO NOT Exceed 60 lb-in of Torgue on 1/4" Connections
- After installation is complete, perform a leak test.

Test button (for AA-A2-6 series only)

When the test button is pressed the 1/4" NPT pressure connection is interrupted and the pressure below the diaphragm is relieved. The pressure switch changes the contact position from NO to NC. When the test button is released, the pressure is built up again and the switch changes to its original position.




1/2" NPT


Ō

Installation Position	
	Standard installation position is vertical upright diaphragm.
	When installed horizontally , the pressure switch switches at a pressure higher by approx. 0.2 in. W.C.
	When installed upside down , the pressure switch switches at a pressure lower by approx. 0.2 in. W.C.
	When installed in other positions , the pressure switch switches at pressure deviating from the set reference value by max. \pm 0.2 in. W.C.
Adjustment	

The scale indicates the setpoint when switch is mounted in the vertical position and increasing pressure.



Application & Connection Examples



AA...A2 is connected to the air duct with

the p2 (-) connection. p1 (+) is not con-

Do not seal the p1 (+) connection; it must


Prevent dirt from entering

into the device through con-

System vacuum monitor


nected with the air duct.

be open to the atmosphere.



Filter monitoring

To monitor a filter, the AA...A2 can be connected as shown above.



Blower monitoring

For blower monitoring, connect connection p1 (+) to the air duct on the downstream side of the blower and connection p2 (-) to the air duct upstream of the blower.

Note: For NFPA 86, a manual reset may be required if this switch trips during operation.

Wiring

nection p1(+)

- 1. Remove the clear cover from the switch.
- 2. Use 14 or 16 AWG wire rated for at least 75 °C.
- 3. Route the wires through the conduit connector.
- 4. Connect the wiring to the appropriate screw terminals.
- 5. Replace the clear cover from the switch.



All wiring must comply with local electrical codes, ordinances and regulations.

Do not exceed the switch ratings given in the specifications and on the switch.


Operation & Adjustment

Adjusting the Set Point

- 1. Remove the clear cover ① from the switch.
- 2. Adjust the switch to the desired set point by turning the dial. The white arrow on the dial indicates the set point @.
- 3. After adjusting the set point, verify that the pressure switch operates as intended by using an accurate pressure gauge connected upstram of the switch.
- 4. Replace the clear cover.

Automatic Reset and Operation

The NC contact of the AA...A2 breaks when pressure rises above the set point. It makes automatically when pressure falls below set point.



AA...A2 switching function As pressure rises above

setpoint: 1 NC opens, 2 NO closes

As pressure falls below setpoint:

2 NO opens, 1 NC closes



MC • Karl Dungs, Inc. • AA...A2 • Edition 2017.07 • P/N 261393



Maintenance & Testing

Annually check the switch for proper operation Set Point Calibration

- Connect a meter capable of reading +/- 0.1 ohms to the NC and COM contacts.
- Measure the resistance across the NC and COM contacts. If the resistance is more than 1.0 ohm, the switch switch should be replaced, since this indicates that the switch contacts are starting to either corrode or carbonizing.
- Apply appressure to the + air pressure connection, and confirm that the NC contact breaks when pressure rises above the set point and that the NO contact makes. the NC contact will make automatically when pressure falls below the set point pressure.
- Connect a meter capable or reading +/- 0.1 ohms to the NO and COM contacts.
- Measure the resistance across the NO and COM contacts. If the resistance is more than 1.0 ohm, the switch switch should be replaced, since this indicates that the switch contacts are starting to either corrode or carbonizing.

Accessories & Replacement	
Accessory for pressure switch	Order No.
Klima-Set (Duct mounting kit)	258247
Mounting plate (flat plastic)	230301 (recommended mounting bracket)
Mounting bracket (plastic)	230273 (optional mounting bracket)
Mounting bracket (metal)	230288 (optional mounting bracket)
Replacement cover (Includes screws and o-rings)	228732
120 VAC light mounting kit (orange)	231772
120 VAC light only (orange)	244156 (for switches with kit 231772 already installed)
24 VDC/VAC light mounting set (orange)	231774
24 VAC light mounting set (green)	248240
Replacement conduit adapter PG 11 to 1/2" NPT	220566
Replacement conduit adapter M20 to 1/2" NPT	240671
DIN connector (female plug)	210318
Male plug for DIN connector 3 PIN without 😑	219659

We reserve the right to make modifications in the course of technical development.

Karl Dungs, Inc. Karl 3890 Pheasant Ridge Drive NE Figure 150 Elaine, MN 55449, U.S.A. Figure 150 Elaine, MN 55449, U.S.A. Figure 150 Figure 763 582-1700 Figure 763 582-1799 Figure 763

Karl Dungs GmbH & Co. KG P.O. Box 12 29 D-73602 Schorndorf, Germany Phone +49 (0)7181-804-0 Fax +49 (0)7181-804-166 e-mail info@dungs.com Internet http://www.dungs.com